

# Air Title V Permit

## Hot Water Heaters, Boilers and Process Heaters

**This applies to** all WDW owned fossil fuel (natural gas, propane, etc.) hot water heaters, boilers, and process heaters, including temporary, new and replacement units. This also applies to existing fossil fuel units being replaced with an electric unit.

**This does NOT apply to** existing electric units and units owned by a third party or OP.



### Air Permitting:

Every single fossil fuel hot water heater, boiler, and process heater (herein to be referred to as “units”) owned by WDW on property is regulated by our WDW Title V Air Permit.

- All new units of any size require an air construction permit *prior* to purchasing the unit. A “new unit” is a unit that is not replacing an existing unit. Contact Environmental Affairs (EA) for permitting. Provide a copy of the new unit’s spec sheet and where the unit will be installed.
- Replacement of existing units  $\geq 10$  MMBtu/hr. heat input will require an air construction permit. Contact EA for permitting. Provide a copy of the new unit’s spec sheet and a picture of the existing units name plate with the serial number clearly visible.
  - Installation of an individual new or replacement unit 10 - 99.9 MMBtu/hr. will also require a dedicated natural gas meter and run hour meter.
- Installation of an individual new or replacement unit  $\geq 100$  MMBtu/hr. heat input is **not allowed**, however, installation of multiple units  $< 100$  MMBtu/hr. heat input in series exceeding 100 MMBtu/hr. is allowed.
- Installation of an electric unit to replace an existing natural gas unit requires notification to EA and a picture of the existing natural gas unit’s name plate with the serial number clearly visible.

### Like-for-Like Replacements:

- **Definition.** A *Like-for-like replacement* is the replacement of an existing unit with one that is of the same or less heat input (MMBtu/hr.). If the replacement unit’s heat input is greater than the existing unit’s, contact EA for next steps.
- **Applicability.** Applies to all existing WDW owned units with a heat input of  $< 10$  MMBtu/hr.
- **Requirements.** All replacement units require an air permit review memo from EA. Email EA a picture of the existing unit’s name plate with the serial number clearly visible and a copy of the new unit’s spec sheet.

### Compliance:

- ➔ EA must report to the state when a new or replacement unit is installed, including like-for-like replacements. EA must also report when an existing unit is removed from service and not replaced or replaced with an electric unit. Email EA as soon as a new/replacement unit is installed or when an existing unit is removed.
- ➔ EA must maintain an accurate inventory of all WDW natural gas hot water heaters, boilers and process heaters on property.

*If you have any questions or need additional information, please contact Environmental Affairs at [www.EnvironmentalAffairs.Air@disney.com](mailto:www.EnvironmentalAffairs.Air@disney.com). (Updated 6/9/2025)*